

United States Postal Service
Switchgear Replacement
Hartford, CT - P&DC
USPS Project No. B43529
A/E Project No. 18034.00

ANSWERS TO RFIs

RFI #45: In the most recent Addendum the attached Riser dated December 8, 2020 was included. This Riser does not match the Bid Set Riser dated September 15, 2021. I have attached both Risers for your review. Please confirm which Riser layout will be required. If it is the one included in the Addendum it will be required to be requoted by our vendors and they have informed us that they would not be able to have the new quote for us by tomorrow.

Answer: Addendum No. 1 included the Power Study Report dated January 11, 2021. Embedded within this report was a copy of the 30% Submission Riser Diagrams dated December 9, 2020 and identified as “NOT FOR CONSTRUCTION”. These drawings shall NOT supersede the Contract Documents dated 9/15/21.